

PROFORMA FOR THE SAFETY CERTIFICATE OF SCHOOL BUILDING

(PART-I)

(To be filled in by the head of school, institute)

1. Name of the School Akal Academy Bilga
2. Location Bilga Talwan Road (15 KM from Phillaur)
3. Plot Area 17 Acres
4. Plinth Area GF+FF+SF(23223.204+23585.49+16974.64)=
63,783.33 Sqm
5. Number of Stories Three
6. Area of Constructed part of the building 1997
7. If the building has been constructed under the supervision of the qualified Engineer, the following details may be given:-
- a) Name of Engineer with qualification Sanjeev Dua (Structural Engg)
- b) Address of the Engineer Civil and Structural Consultants # - 5A
Vijay Nagar Delhi - 110009
- c) If structural drawing used in the construction, if available? _____
- d) Name and address of Architect with qualification Ranjit Singh and Associates
8. Whether the building has been constructed for the purpose of
- a) School Yes/ No
- b) Residential purpose and used for a school Yes/No
9. Materials used for Roofs
- a) R.C.C.Slabs _____
- b) R.S.Joists & Battens _____
- c) Wooden Joints and bottom yes
10. Material used for Walls
- a) Mud Mortar Yes/No
- b) Cement Mortar Yes/No
- c) Lime Mortar Yes/No
11. Flooring
- a) Conglomerate Yes/No
- b) Terrace Yes/No
- c) Brick Paving Yes/No
12. A detailed drawing indicating the doors along with windows and location fitting and windows is attached. yes
13. FOR FIRE SAFETY
- a) Whether the width of the staircase is 1.5 mtr. Yes/No
- b) Whether portable fire extinguisher exists Yes/No
- c) Whether School building is free from inflammable & toxic material Yes/No
- d) Whether cooking of food is done at a safe place Yes/No
- e) Whether any Thatch or combustible material has been used Yes/No

14. Requirement for Fire Protection Arrangements under NB-Part-IV
(For Building height less than 15 metre)

- | | |
|---|--------|
| a) Whether Hose Real provided | Yes/No |
| b) Whether down comer provided | Yes/No |
| c) Whether Automatic sprinkler provided | Yes/No |
| d) Whether underground static water storage tank of capacity 50000 Ltr.(if converted area exceeds 1500 sqm) | Yes/No |
| e) Whether over head tank of capacity 10000 Ltr.exists (in case of hose real) 20000 Ltr. | Yes/No |
| f) Whether one eelectric and one diesel pump of 3 kg/cum Pressure of capacity 1620 LPM, one electric pump of Capacity 180 LPK exist near underground static tank. | Yes/No |
| g) Whether a pump 3 kg/cum pressure & 450/500 LPM Exist near over head tank. | Yes/No |

Sabmi 11/4/2023
Signature of the Head of School/
Principal
Institute

PART-II

(To be filled by the SDE of PWD (B&R) Department)

AKAL ACADEMY BILGA
Distt. Jalandhar (PB)
Affiliated to C.B.S.E. Vide No.1630344

- a) I have visited the above mentioned school on dated 16-5-23 and have visually inspected it from all angles of safety and find it fit for normal use as school building.
- b) In case any addition/alteration or expansion and modifications to this buildings is to be carried out, the same be carried out under the supervision of a qualified Engineer and this certificate may be reobtained after the completion from the undersigned.
- c) In case the building is affected by flood, or if there is settlement of walls/ foundations or sagging of roofs etc. immediate inspection of the undersigned be arranged to check the stability and safety of the building.
- d) This building can be safely occupied for normal use upto (indicate upto which it can be used) upto -01-04-23 to 31-3-24 (2023-24) (under

Normal condition only

NO 138

DT 26/5/23

Sign
Sub Divisional Engineer
Provl. Sub Division
PWD B & R Nakodar.